SCS Global Services *does hereby certify that an independent assessment has been conducted on behalf of:*

Kangda Board (Vietnam) Co., Ltd

Lot 154~165, Linh Trung Export processing and Industrial Zone III, An Tinh Ward, Tay Ninh Province, VietNam

For the following product(s):

Engineered Hardwood:
Multi-Layer Engineered Hardwood Flooring, *Maximum thickness: 18mm*

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-105 Version 4.2 – 2023

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-04214

Valid from: November 01, 2026 to October 31, 2027

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, http://www.scsglobalservices.com/certified-green-products-guide.

Diana Kirsanova Phillips, Chief of Staff to the CEO / Chief Assurance Officer
SCS Global Services