EPH®
SUCCESS BY QUALITY

Entwicklungs- und Prüflabor Holztechnologie GmbH
Zellescher Weg 24 · 01217 Dresden · Germany
www.eph-dresden.de

ilac-MRA DAkkS Deutsche Akkreditierungsstelle D-PL-11054-01-00

accredited by Deutsche Akkreditierungsstelle GmbH (DAkkS)

Deutsches Institut für Bautechnik DIBt

European Notified Body for construction products
0766 Recognized body of DIBt SAC03

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-25-10-10-02

Product: "Engineered Wood Floorings" with different wood species in the top layer, UV-lacquered, Core layer: Birch plywood, Back layer: Birch
Length (400-2200) mm x Width (76-260) mm, Thickness range (8-21) mm

Producer: Kangda Board (Vietnam) Co., Ltd.
Lot 154-165 Linh Trung EPZ & IP III
AN TINH COMMUNE, TAY NINH
VIETNAM

Order: Testing of selected properties according to EN 14342:2013-07 for CE-labelling

Test report: 2708003/356

Test results: The above mentioned floor coverings can be classified regarding to both properties according to EN 14342:2013-07 (CE-labelling) as follows:

Property	Result	Declaration according to EN 14342:2013-07
Formaldehyde emission according to EN 717-1:2004-10	< LOD (144 h)	Class E1
Content of PCP according to CEN/TR 14823:2004	< LOQ	PCP ≤ 5 x 10^{-6n}

LOD = Limit of Detection LOQ = Limit of Quantitation

Dresden, 10/10/2025

Entwicklungs- und Prüflabor Holztechnologie GmbH EPH QUALITY TESTED

Head of laboratory

Engineer in charge